

May 24, 2002

CUST ID No. 242110

ATTN: Plumbing Inspector

WILLIAM R EDWARDS
J F AHERN CO
PO BOX 1316
FOND DU LAC WI 54936

MUNICIPAL CLERK
CITY OF MENOMONIE
800 WILSON AVE
MENOMONIE WI 54751-2734

CONDITIONAL APPROVAL

SITE:

TNT Logistics North America
5929 Packer Ave
City of Menomonie, 54751
Dunn County

Identification Numbers
Transaction ID No. 734157
Site ID No. 642567
Please refer to both identification numbers, above, in all correspondence with the agency.

FOR: Petition for Variance to Comm 81.30 (5) (b) 1.

The submittal described above has been reviewed for conformance with applicable Wisconsin Administrative Codes and Wisconsin Statutes. The submittal has been **CONDITIONALLY APPROVED**. The owner, as defined in chapter 101.01(10), Wisconsin Statutes, is responsible for compliance with all code requirements. Plan submittal and approval by the department or its agent may be necessary prior to construction undertaken per this petition.

Your petition for Variance of the code section noted above has been reviewed.

The code section petitioned requires that the minimum pitch of building drains shall be in accordance with Table 82.30-3. Table 82.30-3 requires that building drain be installed at a minimum 1/16 inch per foot pitch.

The variance requested is to allow the installation of 4" and 6" building drains at a pitch of 1/16 inch per foot.

The intent of the code section petitioned is to provide a velocity of at least 2 feet per second within sanitary building drain piping when the wastewater is flowing half full.

The petitioner submitted the SB-9890 application form.

Reviewer's Comments: **The proposed installation provides the minimum velocity required for sanitary building sewer in the Wisconsin Uniform Plumbing Code. Manning's formula was used to calculate the velocity in the gravity flow piping.**

Department Action: CONDITIONAL APPROVAL

Conditions of Approval:

The following conditions shall be met during construction or installation and prior to occupancy or use:

- **All of the petitioner's statements included on the variance application form, any other documents submitted to the Department and all conditions of approval, if any, listed below should be carried out. This variance is specific to the subject petition and cannot be used for any additional modifications.**
- 1. The installation is limited to this building.**

This decision will become final unless the department within 30 days from the date of this letter receives a written request for a hearing. A request for hearing should be sent to the address shown on this letterhead. A copy of this letter must be included with the request for a hearing. The request for hearing should state the reasons for objecting to the department's decision, because a request for hearing may be denied if it does not present a significant question in fact, law or policy.

Inquiries concerning this correspondence may be made to me at the telephone number listed below, or at the address on this letterhead.

Sincerely,

Lynita M Docken
Program Manager , Program Development
(608) 785-9349, Fax: (608) 785-9330 , Mon - Fri, 7:45 am - 4:30 pm
ldocken@commerce.state.wi.us

Fee Required \$ 225.00
Fee Received \$ 225.00
Balance Due \$ 0.00

WiSMART code: 7657

cc: William R Edwards , J F Ahern Co
Jeff Helegesen , Helgesen Development
J F Ahern Co
Donald D Hough , Plumbing Consultant Ii, (715) 634-4804